Solar Plus Battery Economic Case (Sezibwa)

Data provenance

Underlying data: the aggregate meter meter_100 plus the 10 customer sub-meters, over **2026-03-19 to 2026-08-10**, from the modbus energy-logger archive (sources: pi-direct and nextcloud-import), i.e. the pre- and early-OpenEMS period. Load basis is a conservative 21.3 kWh/day.

Note (2026-08-20): the site has since migrated to **OpenEMS**, which is now the live source. OpenEMS-sourced daily figures from mid-August show inconsistencies (the aggregate roughly doubled exactly at the source switchover, and on some days the customer-meter sum exceeds the aggregate), so they are treated as a data-quality issue to resolve before use; this analysis stays on the validated archive. Phase assignments reflect the wiring as observed up to about May 2026 and should be re-verified against the current OpenEMS setup if any connections have been changed.

Revision #14
Created 2026-08-17 21:53:35 UTC by hillary.arinda
Updated 2026-08-20 07:36:12 UTC by hillary.arinda