

SRNE charge/discharge scheduling registers (self-decoded, #67)

Summary

We self-decoded the SRNE ASP48120SH3 settings registers (V1.7 protocol PDF + a live read-scan of the pilot inverter, firmware v925, 2026-08-09). The key result: **time-of-use charge/discharge scheduling is implemented and writable**, even though real-time active-power dispatch is not. This is the arbitrage lever, and it is not firmware-blocked.

Aaron's SRNE email (2026-08-03) reported that `0xE047-0xE04D` (timed charge/discharge MAX POWER) and `0xE400/E401/E402` (grid active/PF/reactive power) return Modbus "Illegal data address" on our firmware. That is confirmed. But those are a different feature (instantaneous power dispatch). The actual **time-window schedule registers** `0xE026-0xE032` **are RW and implemented**.

Charge / discharge schedule registers (RW, hour*256 + minute)

Register	Function	Live value	Decoded
0xE026	1-section charge start	0	00:00
0xE027	1-section charge stop	1536	06:00
0xE028 / 0xE029	2-section charge start / stop	0 / 0	unused
0xE02A / 0xE02B	3-section charge start / stop	0 / 0	unused
0xE02D / 0xE02E	1-section discharge start / stop	0 / 0	unused
0xE02F / 0xE030	2-section discharge start / stop	0 / 0	unused

Register	Function	Live value	Decoded
0xE031 / 0xE032	3-section discharge start / stop	0 / 0	unused

Encoding: value = hour * 256 + minute. Max 5947 (23*256 + 59 = 23:59). So 1536 = 6*256 + 0 = 06:00.

Current live config: charge window 1 = 00:00 to 06:00 (off-peak), no scheduled discharge. To do TOU arbitrage, set a discharge window over the peak (18:00 to 24:00 = start 4608, stop 6144-ish, i.e. 24:00 as 23:59 = 6143 or 0).

RTC / current time: 0xE034 (year+month) 0xE035 (day+hour) 0xE036 (minute+second) RW; read via 0x020C/0x020D. The inverter's clock must be correct for the schedule to fire at the right wall-clock time - verify it.

Mode / priority registers (RW)

Register	Function	Live	Notes
0xE204	Output priority	3	0/1/2 documented (2 = hybrid, mains+PV, PV preferred); reads 3 on this unit
0xE20F	Charge priority	(def 2)	0-3
0xE216	Start charge time (hour)	1	01:00, "valid for some custom model"
0xE217	Start discharge time (hour)	12	12:00, "valid for some custom model"
0xE205	Mains charge current limit	80	x0.1 A? doc says A; range 0-100
0xE20A	Maximum charge current	80	0-150

Full settings decode (0xE001-0xE039, from V1.7 + live)

Voltage/battery: E002 nominal capacity, E003 system voltage (48), E004 battery type, E005 over-voltage (15.0V), E006 limited-charge (14.4V), E007 equalize, E008 boost/overcharge, E00A boost-return (13.2V-ish), E00B over-discharge-return, E00C under-voltage warn, E00D over-discharge (load cut), E00E limited-discharge, E00F discharge-cutoff SoC (5%), E01B mains-switching voltage, E022 inverter-switching voltage. Times: E010 over-discharge delay (s), E011 equalize time, E012

boost time (min), E023 equalize timeout. The 8 settings the OpenEMS write feature (#53) uses are a subset: E00F, E01C, E01D, E01E, E01F, E020, E205, E20A.

NOT implemented on this firmware (Illegal data address, confirmed live)

0xE047-0xE049 timed discharge max power, 0xE04A-0xE04C timed charge max power, 0xE04D timed charge source, 0xE400 grid active-power set, 0xE401 PF, 0xE402 reactive, 0xE42A battery grid participation, 0xE42C zero-export. So OpenEMS-style instantaneous power dispatch is not available; TOU scheduling is the achievable control.

What this unlocks for NFE

TOU arbitrage via scheduling: set the charge window to off-peak (already 00:00-06:00) and add a discharge window over the peak tariff, using 0xE026-0xE032. All RW, all validated readable live. Next: a careful readback-verified live write test of one discharge window (write, verify, restore), then integrate scheduled writes (guarded, like #53) so NFE can shift the battery by tariff without a site visit.

Method / traceability

Live read-scan via mbpoll (edge + nfe-monitor stopped to free the RS485 bus), firmware v925, 2026-08-09. Decoded against SRNE_Hybrid_Inverter_MODBUS_protocol_V1.7.pdf (repo: NFE/CUSTOM_CODE/srne-products). Related: register map (page 126), mbpoll reference (page 125), safe settings write (page 128, #53). Issue logger #67.

Revision #1

Created 2026-08-09 15:30:53 UTC by hillary.arinda

Updated 2026-08-09 15:30:53 UTC by hillary.arinda